



Office of the District Fire Officer,
Anjanapura Fire Station,
Bengaluru.



No. 45 /DFO/AFS/Bng/FSR/2023

Dated: 10-07-2023.

ANNEXURE - 1
Group - B Educational Building

To,
The General Manager,
M/s. Rashtrothana Parishat,
Keshava Shilpa,
Kempegowda Nagar,
Bangalore 560 019.

Sir,

Sub : Issue of "Fire safety recommendation" with respect of fire prevention, fire fighting and evacuation measures required at "M/s. Rashtrothana Parishat, Katha No.579, 18/1, Ramamurthy Nagar, Bangalore 560 016" - reg.

Ref : 1) Your request letter dated: 19-06-2023.
2) Inspection report No: 120/FSTO/AFS/2023 Date: 08-07-2023.

<<<<>>

With reference to the subject cited above, the premises of "M/s. Rashtrothana Parishat, Katha No.579, 18/1, Ramamurthy Nagar, Bangalore 560 016" was inspected by the Fire Station Officer, Anjanapura Fire Station, Bengaluru on 07-07-2023 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

A. Details of the building / premises :-

01	Name and Address of the Applicant.	: The General Manager, M/s. Rashtrothana Parishat, Keshava Shilpa, Kempegowda Nagar, Bangalore 560 019.
02	Name and Address of the premises.	: M/s. Rashtrothana Parishat, Katha No.579, 18/1, Ramamurthy Nagar, Bangalore 560 016.
03	Name and address of the Building owner	: The General Manager, M/s. Rashtrothana Parishat, Keshava Shilpa, Kempegowda Nagar, Bangalore 560 019.
04	Number of buildings	01 Building.

PRINCIPAL
JAIGOPAL GARODIA RASHTROTHANA
VIDYA KENDRA
Main Road, Ramamurthy Nagar,
BENGALURU 560 019.



Correspondent
JAIGOPAL GARODIA RASHTROTHANA
VIDYA KENDRA
Main Road, Ramamurthy Nagar
BENGALURU 560 016.



Office of the District Fire Officer
Anjanapura fire Station
Bengaluru.



No.45/DFO/AFS/Bng/FSCR/2023

Dated: 10-07-2023.

"Annexure-2"

To,
The General Manager,
M/s. Rashtrorathana Parishat,
Keshava Shilpa,
Kempegowda Nagar,
Bangalore 560 019.

Sir,

Sub : Issue of "Fire Safety Compliance report" with respect to fire prevention, fire fighting and evacuation measures maintained at "M/s. Rashtrorathana Parishat, Katha No.579, 18/1, Ramamurthy Nagar, Bangalore 560 016" - reg.

Ref : 1) FSR No.45/DFO/AFS/Bng/FSR/2022 Date: 10-07-2023.
2) Your request letter dated: 19-06-2023.
3) Inspection report no: 120/ FSTO/AFS/2023 Date: 08-07-2023.

<<<<>>

With reference to the above cited subject, as per ref (1), a conditional Fire Safety Recommendation was issued to the premises of "M/s. Rashtrorathana Parishat, Katha No.579, 18/1, Ramamurthy Nagar, Bangalore 560 016" with a condition to fulfill the recommendations and compliance the same within 3 months.


With reference cited (2) above, the management of "M/s. Rashtrorathana Parishat" had requested for the fire safety compliance report from our department. In this regard the Fire Station Officer, Anjanapura Fire Station, Bengaluru was inspected on 07-07-2023 and submitted the report to issue fire safety Compliance report.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the "Fire Safety Compliance Report" to "M/s. Rashtrorathana Parishat, Katha No.579, 18/1, Ramamurthy Nagar, Bangalore 560 016" subject to proper maintenance of fire fighting installations in the good working conditions and arrange for 40% of staffs/ employees training within 03 months from the date of issue of this report. "This report is valid up to only one year from the date of issue and is renewable without fail".

Copy to: Fire Station Officer,
-Anjanapura Fire Station, Bengaluru.



PRINCIPAL
JAIGOPAL GARODIA RASHTRORATHANA
VIDYA KENDRA
Main Road, Ramamurthy Nagar,
BENGALURU 560 016.



Yours faithfully,

DISTRICT FIRE OFFICER
Anjanapura Fire Station,
BENGALURU - 560 108.


Correspondent
JAIGOPAL GARODIA RASHTRORATHANA
VIDYA KENDRA
Main Road, Ramamurthy Nagar
BENGALURU 560 016.

Sl. No (1)	Details (02)	Existing (03)		Recommendations (04)
1.	Accessibility to the premises	The premise is accessible from 12.00 mtrs wide Outer Ring Road, located on the northern side & it is hardened to carry the weight of 45,000 kgs capacity.		Complied.
2.	No. of entrances	01 entry cum exit of 6.00 mtrs width has been Provided.		Complied.
3.	Diesel generators.	One diesel generator of 62.50 KVA capacity has been provided and it is connected to all the emergency provisions in the building.		Complied.
4.	Number of staircases available	No. of staircases	02	Complied.
Width of staircases		Each of 1.50 mtrs.		
Width of treads		30 cms		
Height of risers		15 cms		
Nos. of riser per flight		12 nos.		
Height of handrails		1.00 mtr.		
Head room clearance		2.40 mtrs		
5.	Portable Fire extinguishers	One ABC type extinguisher of 6 kgs capacity for every 100.00 Sq.mtrs built up area & 02 nos. CO2 extinguishers, each of 4.5 kgs capacity near electrical boards have been provided.		Complied.
7	First aid hose reel hose	02 Hose reel hose systems near the staircase have been provided. The hose reel hose of 19 mm size and of adequate length to reach the farthest point of the floor have been provided with shut off branch having a nozzle of 5 mm size. The hose reel hose have been connected at each landing.		Complied.
6.	Terrace tank over respective tower terrace.	The hose reel hose systems have been connected to an overhead tank of 10,000 liters water capacity exclusively for firefighting purpose.		Complied.


PRINCIPAL
 JAIGOPAL GARODIA RASHTROTTHANA
 VIDYA KENDRA
 Main Road, Ramamurthy Nagar,
 BENGALURU 560 016.




 Correspondent
 JAIGOPAL GARODIA RASHTROTTHANA
 VIDYA KENDRA
 Main Road, Ramamurthy Nagar
 BENGALURU 560 016.

05	Number of floors	:	Ground floor & 3 upper floors.
06	Floor-wise details of occupancy:-		
	Ground floor	:	11 Class rooms, Library room, 2 Store rooms, Principal room, Lobby / waiting area, Administrator room, Admin office, Staff room & Computer room.
	1 st floor	:	11 Class rooms, Library- secondary room, 2 Computer rooms, Language room, Maths lab, 2 Store rooms & Staff room.
	2 nd floor	:	11 Class rooms, 2 Computer rooms, Language room, Chemistry lab, 2 Store rooms & Staff room.
	3 rd floor	:	11 Class rooms, 2 Computer rooms, Language room, Physics lab, 2 Store rooms & Staff room.
07	Height of the building	:	14.00 mtrs.
08	Site area	:	6,821.07 Sq.mtrs.
09.	Built-up area of each floor:-		
	Ground floor	:	1,683.65 Sq.mtrs
	1 st floor	:	1,623.31 Sq.mtrs
	2 nd floor	:	1,671.10 Sq.mtrs
	3 rd floor	:	1,671.10 Sq.mtrs
	Terrace floor	:	58.56 Sq.mtrs
10.	Total built-up area	:	6,707.72 Sq.mtrs
11.	Surrounding properties:-		
	Front (North)	:	12.00 mtrs wide Outer Ring Road.
	Rear (South)	:	Private property.
	Side (East)	:	Private property.
	Side (West)	:	Private property.
12.	Set-back area available around the building :-		
	Front (North)	:	6.00 mtrs
	Rear (South)	:	6.00 mtrs
	Side (East)	:	6.00 mtrs.
	Side (West)	:	6.00 mtrs.

B. On inspection of this School premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view:-

PRINCIPAL
JAIGOPAL GARODIA RASHTROTTHANA
VIDYA KENDRA
 Main Road, Ramamurthy Nagar,
 BENGALURU 560 016.



[Signature]
 Correspondent
JAIGOPAL GARODIA RASHTROTTHANA
VIDYA KENDRA
 Main Road, Ramamurthy Nagar
 BENGALURU 560 016.

7.	At the terrace tank level with minimum pressure of 3.5 kg/cm ²	The hose reel hose systems have been connected to Booster pump capable of delivering 450 LPM with minimum pressure of 3.5 kg/cm ² .	Complied.
8.	Escape routes	Directions in which the students have to move in the event of an emergency have been displayed in the corridor on each floor during evacuation.	Complied.
9.	Fire order (Fire Safety plans)	A notice board have been indicated the action have been taken by the employees in case of any emergency have been displayed with the telephone number of nearest fire station & 101, 500 550, & 600 and the nearest Ambulance service and Police Station.	Complied.
10.	No smoking board.	No smoking boards have been displayed.	Complied.
11.	Fire Fighting training	Not Trained	40% of the staffs/Teachers shall be got trained in fire prevention, fire fighting & evacuation at R.A.Mundkur fire & emergency service Academy, Bannerghatta road, Bangalore-560 029.

12. Fire precautionary measures :-

- A) Explosive and flammable materials should not be stores in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.
- B) Accumulation of combustible waste in and the premises should be avoided.
- C) The exit ways shall be always kept clear without any obstruction.
- D) Liquefied petroleum gas should not be stores in the building.
- E) The doors shall not be kept locked / latched during working hours and shall be free from obstruction.
- F) During the class hours the class room doors shall not be locked from inside to out side.
- G) As per Honorable Supreme Court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year be conducting Fire Safety drills with the Fire Safety Day on April 14th of every year be conducting Fire Safety drills with

JAIGOPAL GARODIA RASHTREEVA VIDYA KENDRA
Main Road, Ramamurthy Nagar,
BENGALURU 560 016.



Correspondent
JAIGOPAL GARODIA RASHTREEVA VIDYA KENDRA
Main Road, Ramamurthy Nagar,
BENGALURU 560 016.

- H) Karnataka State Fire & Emergency Services Department has issued this Fire Safety Recommendation only for low building (below 15.00 mtrs). In case the Applicant has constructed additional floors over the existing floors of this buildings and increase the building height above 15.00 mtrs. Then Department has not responsible for any situation and also this fire safety recommendation shall stand withdrawn/cancelled.
- I) This Fire Safety Recommendation is issued from the fire prevention, fire fighting and evacuation measures. Karnataka State Fire & Emergency Services Department is not responsible for the ownership of the land, its location and other disputes, which may arise in due course.

Under the above circumstance, the Karnataka Fire & Emergency Services Department is issuing Fire Safety Recommendation to "M/s. Rashtrotthana Parishat, Katha No.579, 18/1, Ramamurthy Nagar, Bangalore 560 016" subject to condition and compliance of the above recommendations as shown in Column-4 of Part-B within 3 months and compliance from the undersigned.

"This Fire Safety Recommendation is valid for Only One Year from the date of issue and it is renewable."

All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.3 of Fire and Life safety will have to be complied with mandatorily.



Yours faithfully,
[Signature]
DISTRICT FIRE OFFICER
Anjanapura Fire Station,
BENGALURU - 560 108.

Copy to: Fire Station Officer,
Anjanapura Fire Station, Bengaluru.

[Signature]
PRINCIPAL
JAIGOPAL GARODIA RASHTROTTHANA
VIDYA KENDRA
Main Road, Ramamurthy Nagar
BENGALURU 560 016

[Signature]
Correspondent
JAIGOPAL GARODIA RASHTROTTHANA
VIDYA KENDRA
Main Road, Ramamurthy Nagar
BENGALURU 560 016